

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIRECTOR GENERAL
WEST BENGAL FIRE & EMERGENCY SERVICES
13-D Mirza Ghalib Street, Kolkata- 700 016**

Memo No : IND/WB/FES/20192020/88751

DATE:27/02/2020

**From :
The Director
Fire Prevention Wing,
West Bengal Fire & Emergency Services.**

To :

**SRI RAMKRISHNA TRUST BOARD,
KARIMPUR ANITA P T T I AND KARIMPUR ANITA B ED COLLEGE,
KARIMPUR-I, TEHATTA,
P.O-SENPARA, P.S-KARIMPUR,
DIST-NADIA,
PIN-741152**

Sub : Fire Safety Certificate for the occupancy for an existing construction of: G + 1 storied building of Educational at the Premises No.- KARIMPUR ANITA P T T I AND KARIMPUR ANITA B ED COLLEGE, SRI RAMKRISHNA TRUST BOARD, VILL.- MADHYAGOPALPUR, P.O.- SENPARA, P.S.- KARIMPUR, DIST.- NADIA, WEST BENGAL, PIN - 741152.

This is in reference to your Application No. IND/WB/FES/20192020/88751, dated 08/02/2020, regarding the Fire Safety Measure for an existing construction of G + 1 storied building under group of Educational at the Premises No.- KARIMPUR ANITA P T T I AND KARIMPUR ANITA B ED COLLEGE, SRI RAMKRISHNA TRUST BOARD, VILL.- MADHYAGOPALPUR, P.O.- SENPARA, P.S.- KARIMPUR, DIST.- NADIA, WEST BENGAL, PIN - 741152.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

1. Driveway must be free of any type of obstruction for easy movement of fire appliances. No parking will be allowed on the drive way. Basement shall not be used other than Car parking.
2. The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specifications.
3. To eliminate risk of fire hazard, good housekeeping both for inside and outside of the building shall be strictly maintained.
4. Existing electrical wiring of the whole building shall have to be carefully checked for any were and tear in them, particularly lines above false ceiling and ducts.
5. The employees and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event of Fire and Testing.
6. Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.
7. Transformer and switchgear room shall be protected with automatic co2 or DCP fire extinguisher conforming I.S specification.
8. First aid firefighting system shall be provided as per I.S specification.
9. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipment's installed in the building to keep them in perfectly good working conditions at all times.
10. Fire License shall have to be obtained for storing and processing with highly combustible articles.
11. The Fire Safety Certificate is valid for a period of three year from the date of issue, and has to be renewed after three year certifying about the satisfactory services, performance of all the Life and Fire Safety arrangements installation of the building.

Director
West Bengal Fire & Emergency Services

Signature valid

Digitally signed by ARUN
KUMAR SEN
Date: 2020.09.27 21:33:20 IST