



सत्यमेव जयते

Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
Azad Hind Sarak, P.O.:- Ghurni, P.S.:- Kotwali, Pin :- 741103

Memo No.: FSR/IND/WB/FES/20192020/88751

Date : 08-07-2026

From :
Divisional Fire Officer
Nadia Division,
West Bengal Fire & Emergency Services

To :
KARIMPUR ANITA P.T.T.I & KARIMPUR ANITA B.ED. COLLEGE
VILL-MADHYAGOPALPUR,P.O-SEN PARA,P.S-KARIMPUR,DIST-NADIA,WB

Sub : Renewal of Fire Safety Certificate in favour of Existing construction of G+I storied Educational building under group of Educational Institution in the name & style- Karimpur Anita PTTI and Karimpur Anita B. Ed College, at the premises No. Dag No. LR-127, 133, 134, RS- 133, 110, 101, Khatian No. 422/1, 779, J.L No. 8, Mouza- Madhyagopalpur, under Karimpur Gram Panchayat, Vill:- Madhyagopalpur, PO:- Sen Para, PS:- Karimpur, Dist:- Nadia, Pin-741155, West Bengal.

This is in reference to your AIN 211912606300011670 dated 03-Jul-2026 regarding Renewal of Fire Safety Certificate in favour of Existing construction of G+I storied Educational building under group of Educational Institution in the name & style- Karimpur Anita PTTI and Karimpur Anita B. Ed College, at the premises No. Dag No. LR-127, 133, 134, RS- 133, 110, 101, Khatian No. 422/1, 779, J.L No. 8, Mouza- Madhyagopalpur, under Karimpur Gram Panchayat, Vill:- Madhyagopalpur, PO:- Sen Para, PS:- Karimpur, Dist:- Nadia, Pin-741155, West Bengal..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Renewal of Fire Safety Certificate** for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated maintained.

Recommendation:



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912606300011670

1. Driveway must have to be kept free of obstruction at all time for EASY movement of fire Appliances. No parking will be allowed on the driveway.
2. The interior finish decoration of building shall be made with low flame spread material confirming I.S. specification.
3. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the Building shall be strictly maintained.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for any damage in wear and tear in them, particularly lines above false ceiling & ducts.
5. A fire control room including a close circuit T.V./ Monitor system will have to be installed which will observe all the floor of the Building.
6. The notice of Fire Fighting equipments and Evacuation plan shall be maintained and displayed at all venerable places of the Building.
7. The Employees and security staff shall be well conversant with installed Fire Fighting Equipments of the building and to operate in the event of Fire and Testing.
8. Mock Fire practice evacuation drill shall to be performed periodically with participant of all the occupants of the building.
9. Main and meter room shall be protected with Co2 or DCP Fire Extinguishers confirming I.S. Specifications.
10. First-Aid Fire Fighting system shall be provided as per I.S. Specification.
11. Arrangement shall have to be made for regular checking, testing and maintenance, of all the Fire Fighting installation of the Building to keep them in perfectly good working Condition at all the time.
12. If required the old line shall have to be replaced with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
13. Periodical Flashing of water in hydrants pipe line shall be made to maintain the efficient working performance of above mentioned system.
14. Fire Safety audit to be conducted at regular interval and to be recorded in the fire prevention maintenance register.
15. Transformer & switch Gear room (if applicable) shall be protected with CO2 or D.C.P. Fire Extinguisher conforming I.S. Specification.
16. Storage of volatile flammable liquid shall be prohibited and the handling of such liquids shall restricted to science Laboratory only.
17. If gas use in the laboratory shall be provided with an approve out side gas shut-off valve conspicuously marked.
18. Fire Licence shall have to be obtained from the licence section of the department for proposed storing of highly combustible articles and procession with L.P.G., which come under purview of licence section as per Fire service Act-1950 (with up to date amendment).
19. **One No of stand by pump of the same capacity shall have to be installed within six(06) months from the date of issue of this letter & inform to this office.**
20. This **Fire Safety Certificate** is valid for Three years and have to be renewed every three years interval from the date of Issue of this letter. In every three years Certificate is to be obtained from the **Director General, West Bengal Fire & Emergency Services**, regarding the **Performance** of all the life & Fire Safety arrangements and installation of the Building.
21. Any deviation or changes the building in respect of the approved plan drawing, without prior permission from this office, this fire safety certificate will be treated cancelled automatically.

Valid Upto : 06-Jul-2029



Signature valid

Digitally Signed.
Name: SUBNATA GUHA
Date: 08-Jul-2026 15:18:25
Reason: D-Sign
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912606300011670